

### **CODE NUMBER**

24501320

#### **DESCRIPTION**

ST-2459 Water Closet and SLOAN 111 ESS Flushometer.

### **COMPONENTS**

Flushometer: Code 3770035Water Closet: Code 2102459

### **DETAILS**

• Flush Volume: 1.28 gpf (4.8 Lpf)

Nominal Dimensions: 26 <sup>3</sup>/<sub>4</sub>" × 15" × 13 <sup>1</sup>/<sub>4</sub>" (679 × 381 × 337mm)

## **FLUSHOMETER FEATURES**

- Flush volumes start as low as 1.6 gpf/6.0 Lpf
- Courtesy FlushTM Non-Hold-Open True Mechanical Override
- Water conservation is aided by the non-hold-open push button, which prevents toilet from exceeding intended flush volume
- Integrity of the product is maintained with the vandal-resistant stop cap
- Durability is facilitated with high copper, low zinc brass castings for dezincification resistance
- Adjustable tailpiece to accommodate different height requirements
- Dual-Filtered Fixed Bypass Diaphragm
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Semi-Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037.

# **FIXTURE FEATURES**

- White Vitreous China
- Elongated bowl
- Wall mounted, wall outlet
- Siphon jet flushing action achieves 1000g Map score when used with any Sloan flushometer
- Static load rating of 750 lbs (see Notes)
- Water spot area: 101/8" x 93/8" (26 cm x 24 cm)
- 1½" I.P.S. top spud inlet
- 2½" fully glazed trapway
- Toilet seat not included
- Static load rating of 750 lbs. (See Notes)



## **COMPLIANCES & CERTIFICATIONS**



















(ADA Compliant, BAA Compliant, BREEAM Water Credit, EPD, Green Globes Water Credit, HPD, LEED V4 Water Efficiency Credit, Satisfies LEED Credits, WaterSense Listed, WELL Building Standard)

### **DOWNLOADS**

- Sloan / Regal ESS TMO Installation Instructions
- ST-2459 Installation Instructions
- SS/ST/SU/WETS/WEUS Fixtures Repair and Maintenance Guide
- Optima ESS TMO Concealed Repair and Maintenance Guide
- Additional Downloads

### NOTES

All information contained within this document subject to change without notice.


Static load tested according to the procedure outlined in Section 6.7 of ASME A112.19.2. Not recommended for bariatric use.


## WARRANTY

View Warranty Information



# **ROUGH-IN**





Phone: 800.982.5839 • Fax: 800.447.8329 • sloan.com