

# OPTIMA® SENSOR FAUCET ETF-600-HLT-TEE-PB-0.5GPM-MLM-FCT

(General Model Name: ETF600-LT PVDPB ELECTRONIC FAUCET)

Discontinued

## **CODE NUMBER**

3365262BT

#### DESCRIPTION

Bluetooth, Hardwired Less Transformer Power Supply, Back-Check Tee, Polished Brass Finish, 0.5 gpm, Multi-Laminar Spray, Infrared Sensor, Optima® Hardwired-Powered Deck-Mounted Low Integrated Base Body Faucet.

#### **DETAILS**

Flow Rate: 0.5 gpm (1.9 Lpm) (0.5GPM)
Spray Type: Multi-Laminar (MLM)

• Sensor Type: Infrared

• Mounting Type: 4" Centerset

Mounting Size: 4" Centerset, (3-hole) 1-1/4" to 1-1/2"
 Power Supply: Hardwired Less Transformer (HLT)

• Temperature Mixer: Back-Check Tee (TEE)

• Finish: Polished Brass (PB)

Factory Default Timeout: 30 secondsFactory Default Gallons per Cycle: 0.25

#### **FEATURES**

Commercial Grade Faucet, ADA Compliant, Cast Brass Spout, Quick Connect Fittings, Integrated Water Shut-off, Wireless Settings Adjustment, On-demand or Metered activation, Hygienic Line Flush, Water Usage and Battery Strength Reporting, Self-adapting Sensor

### **ELECTRICAL SPECIFICATIONS**

- Battery Life: 3 years 8,000 cycles/month
   Optional power harvesting significantly extends service life
- Sensor Range: 4"-5" (102-127mm)
  Timeout Adjustment Settings: 30s

# **POWER SUPPLY OPTIONS**

- 6VDC Plug Adapter (included with PLG models), 0362006
- 6VDC Ganged Adapter Kit (up to 6 units)(sold separately), 0362035\*
- 24VAC Box Transformer (included with BOX models), 0345370PK
- \* when converting units to hardwired with battery back-up

## **VIDEOS**

Sloan Connect App®


Sloan Optima Below Deck Faucet

PVD Special Finishes

## DOWNLOADS

- Optima Smart Faucet Below Deck Installation Instructions
- Trim Plate Guide
- Faucet Spray Heads Repair and Maintenance Guide
- ETF-600/EBF-650 Below Deck Repair and Maintenance Guide





### **COMPLIANCES & CERTIFICATIONS**































(ADA Compliant, ASME A112.18.1 Compliant, CalGreen Compliant, CEC Compliant, cUPC Certified, cUPC Low Lead Compliant, EPD, GPC 0.25 or less, HPD, IAPMO, NSF-61, NYC604.4, Proposition 65, TAS, UPC Certified, UPC Low Lead Compliant, WaterSense Listed, WELL Building Standard)

## NOTES

All information contained within this document subject to change without notice.

Looking for other variations of the ETF-600 product? View the general spec sheet with all options.

Find a matching soap dispenser for this faucet. Find a compatible sink for this faucet.

## WARRANTY

View Warranty Information



# OPTIMA® SENSOR FAUCET ETF-600-HLT-TEE-PB-0.5GPM-MLM-FCT

(General Model Name: ETF600-LT PVDPB ELECTRONIC FAUCET)

Discontinued

• Additional Downloads

**Sloan 10500 Seymour Ave, Franklin Park, IL 60131** Phone: 800.982.5839 • Fax: 800.447.8329 • sloan.com




Discontinued




## **ROUGH-IN**

# ETF-600 Faucet with Bak-Chek® Tee for Hot and Cold Water Supply



# ETF-600 Faucet with BDM and BDT Variation Mixing Valves for Hot and Cold Water Supply



Phone: 800.982.5839 • Fax: 800.447.8329 • sloan.com